

Indiana State Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 000162	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 09/24/2012
NAME OF PROVIDER OR SUPPLIER WILLIAMSBURG HEALTH & REHAB		STREET ADDRESS, CITY, STATE, ZIP CODE 1609 LAFAYETTE RD CRAWFORDSVILLE, IN 47933		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 09/24/12</p> <p>Facility Number: 000162 Provider Number: 155261 AIM Number: 100284300</p> <p>Surveyor: Dennis Austill, Life Safety Code Supervisor</p> <p>At this Quality Assurance Walk-thru survey, Williamsburg Health & Rehabilitation was found in compliance with 410 IAC 16.2-3.1-19(ff)</p> <p>This one story facility was determined to be of Type II (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors and areas not separated from the corridor. The facility has battery operated smoke detectors in 58 resident rooms. The facility has a capacity of 116 and had a census of 74 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and in compliance in regard to smoke detector coverage.</p> <p>All areas where the resident have customary access were sprinklered. The facility has two detached wood mini barns used for storage. Both mini barns were not sprinklered.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 09/26/12.</p>	K 000		

Indiana State Department of Health

TITLE

(X6) DATE

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

STATE FORM

6899

ELYJ21

If continuation sheet 1 of 1